



2018 IECC Residential Energy Code Test Form

International Energy Conservation Code (402.4.1.2/403.3.4)

Job Address: _____

Job Permit #: _____

House Sq. Footage (conditioned area): _____

402.4.1.2 Air Sealing and Insulation (Blower Door) test results: _____ ACH

Results: Pass Fail (Air leakage shall be ≤ 5 air changes per hour (ACH) in Climate Zones 1 & 2, and ≤ 3 air changes per hour (ACH) in Climate Zones 3-8 when tested with a blower door at 50 Pa) ***Per NCTCOG Recommended Amendments; Section R402.4.1.2, the air leakage rate shall not exceed 5 air changes per hour.*

403.3.4 Duct Tightness (Duct Blaster) test results: _____ CFM/100 sq²

Results: Pass Fail

(Check applicable below)

Post Construction Test:

Total leakage ≤ 4 cfm per 100 sq² of conditioned floor area when tested at a pressure differential 25 Pa across the entire system, including the manufacture's air handler enclosure.

Rough-in test:

Total leakage shall be ≤ 4 cfm per 100 sq² of conditioned floor area when tested at a pressure differential 25 Pa across the entire system, including the manufacture's air handler enclosure. IF the air handler is not installed at the time of the test, total leakage shall be ≤ 3 cfm per 100 sq² of conditioned floor area.

Exceptions: Duct tightness test is **NOT** required if the air handler and all ducts are located within the conditioned space.

This building has been designed, built, and hereby certified to comply with the IECC 2018 Energy Code.

Tester's Name: _____

Signature: _____ Date: _____