



BACKFLOW PREVENTION ASSEMBLY TEST AND MAINTENANCE REPORT

The following form must be completed for each assembly tested. A signed and dated original must be submitted to the public water supplier for recordkeeping *purposes:

NAME OF PWS: City of Sanger
PWS ID#: TX0610006
PWS MAILING ADDRESS: PO Box 1729, Sanger, TX 76266
PWS CONTACT PERSON: Jim Bolz
ADDRESS OF SERVICE:

The backflow prevention assembly detailed below has been tested and maintained as required by commission regulations and is certified to be operating within acceptable parameters.

TYPE OF BACKFLOW PREVENTION ASSEMBLY (BPA):

Reduced Pressure Principle (RPBA)
Double Check Valve (DCVA)
Pressure Vacuum Breaker (PVB)
Reduced Pressure Principle-Detector (RPBA-D) Type II
Double Check-Detector (DCVA-D) Type II
Spill-Resistant Pressure Vacuum Breaker (SVB)

Manufacturer: Main: Bypass: Size: Main: Bypass:
Model Number: Main: Bypass: BPA Location:
Serial Number: Main: Bypass: BPA Serves:

Reason for test: New Existing Replacement Old Model/Serial #
Is the assembly installed in accordance with manufacturer recommendations and/or local codes?
Is the assembly installed on a non-potable water supply (auxiliary)?

TEST RESULT
Reduced Pressure Principle Assembly (RPBA)
DCVA
1st Check 2nd Check*** Relief Valve
Type II Assembly
PVB & SVB
Bypass Check Air Inlet Check Valve
Initial Test
Date: Time:
Held at psid Closed Tight Leaked
Held at psid Closed Tight Leaked
Opened at psid Did not open Did it fully open
Held at psid Closed Tight
Held at psid Opened at psid Held at psid

*** 2nd check: numeric reading required for DCVA only

Differential pressure gauge used: Potable: Non-Potable:
Make/Model: SN: Date tested for accuracy :

Remarks:

Company Name: Licensed Tester Name (Print/Type):
Company Address: Licensed Tester Name (Signature):
Company Phone #: BPAT License # License Expiration Date:

The above is certified to be true at the time of testing.

* TEST RECORDS MUST BE KEPT FOR AT LEAST THREE YEARS [30 TAC §290.46(B)]

** USE ONLY MANUFACTURER'S REPLACEMENT PARTS